CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 6911-0065:181 Page 1 of 1

CATEGORY: Voice Communication Systems Control Units

LISTEE: Faraday Inc., *8 Fernwood Road, Florham Park, NJ 07932-1906

Contact: *Peter Pawchak (973) 593-2662 FAX (973) 593-6652

DESIGN: Models VPS50 and VPS50E audio adjunct system. The unit is intended to be used in

> conjunction with separately listed electrically compatible speakers and fire alarm control unit to provide voice communication, paging, evacuation tone signals, and voice alarm signals with voice override. Refer to listee's data sheet for additional detailed product

description and operational considerations.

RATING: Input: 24-30 VAC/DC, Standby: 24 VDC, 7 Ah Battery

INSTALLATION: In accordance with listee's printed installation instructions, wiring diagram, applicable codes

and ordinances and in a manner which is acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a voice evacuation/communication/audio adjunct system for use with a

> separately listed electrically compatible fire alarm speakers and control unit. Supervision is dependent upon the fire alarm control panel. Refer to the control panel's listing and installation instructions for proper configurations. Authority having jurisdiction should be

consulted prior to installation.

XLF: 6911-1446:102

07-26-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 18, 2004 Date Issued: Listing Expires June 30, 2005

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager